

Certificate of Conformity

This is to certify that the cement sample

Solid Plus (CEM II/A-P 42.5 N) Cement, CTLGroup ID 4399801

submitted and identified by: **Holcim (Azerbaijan)**
received at CTLGroup on February 28, 2017

meets the sulfate resistance requirements of ASTM C1157-17, *Standard Performance Specification for Hydraulic Cement*, for **Type HS (high sulfate Resistance) cement**.

Test method: ASTM C1012/C1012M-15, *Standard Test Method for Length Change of Hydraulic-Cement Mortars Exposed to a Sulfate Solution*.



Xiuping Feng, CTLGroup project manager

April 6, 2018

CTLGroup
5400 Old Orchard Road
Skokie, Illinois 60077
(847) 965-7500

www.CTLGroup.com



B u i l d i n g K n o w l e d g e . D e l i v e r i n g R e s u l t s .